

Air System Sizing Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

Air System Information

Air System Name **Rest - Floor 1 Zone 1**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1829.8** ft²
Location **London - Kew, United Kingdom**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Central Cooling Coil Sizing Data

Total coil load **6.7** Tons
Total coil load **80.9** MBH
Sensible coil load **67.3** MBH
Coil CFM at Aug 1600 **3045** CFM
Max block CFM **3045** CFM
Sum of peak zone CFM **3045** CFM
Sensible heat ratio **0.832**
CFM/Ton **451.4**
ft²/Ton **271.3**
BTU/(hr-ft²) **44.2**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Aug 1600**
OA DB / WB **82.4 / 68.0** °F
Entering DB / WB **76.6 / 63.8** °F
Leaving DB / WB **56.1 / 54.7** °F
Coil ADP **53.3** °F
Bypass Factor **0.120**
Resulting RH **50** %
Design supply temp. **55.0** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **64.8** MBH
Coil CFM at Des Htg **3045** CFM
Max coil CFM **3045** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **35.4**
Ent. DB / Lvg DB **65.4 / 85.2** °F

Supply Fan Sizing Data

Actual max CFM **3045** CFM
Standard CFM **3043** CFM
Actual max CFM/ft² **1.66** CFM/ft²

Fan motor BHP **1.67** BHP
Fan motor kW **1.32** kW
Fan static **2.00** in wg

Outdoor Ventilation Air Data

Design airflow CFM **549** CFM
CFM/ft² **0.30** CFM/ft²

CFM/person **10.98** CFM/person

Zone Sizing Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

Air System Information

Air System Name **Rest - Floor 1 Zone 1**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1829.8** ft²
Location **London - Kew, United Kingdom**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/ft ²	Reheat Coil Load (MBH)	Reheat Coil Water gpm @ 20.0 °F	Zone Htg Unit Coil Load (MBH)	Zone Htg Unit Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	3045	3045	1.66	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (ft ²)
Zone 1	64.0	Jul 1900	56.9	1829.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
Bar Kitchen	1	33.3	Aug 1600	1541	26.2	1047.1	1.47
Brew KIT	1	5.5	Jun 2100	255	3.1	92.9	2.74
Dining Space	1	12.0	Jun 1900	554	10.0	273.0	2.03
fwc1	1	1.1	Jul 2200	52	1.3	20.1	2.57
fwc2	1	1.0	Jul 2100	47	1.1	18.6	2.53
fwc3	1	1.1	Jul 2100	50	1.3	20.6	2.43
fwc4	1	1.4	Jul 2100	65	1.7	36.4	1.78
KEG Store	1	1.9	Jul 2100	87	2.6	69.3	1.26
Mwc	1	2.5	Jul 2100	118	2.4	66.6	1.77
staff	1	2.2	Jul 2100	101	2.2	50.9	1.99
staff bath	1	1.1	Jul 2100	49	1.2	18.0	2.74
Wash up	1	2.7	Jun 2000	125	3.9	116.3	1.08

Ventilation Sizing Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

1. Summary

Ventilation Sizing Method **Sum of Space OA Airflows**
Design Ventilation Airflow Rate **549** CFM

2. Space Ventilation Analysis

Zone Name / Space Name	Mult.	Floor Area (ft²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1									
Bar Kitchen	1	1047.1	20.0	1541.4	7.50	0.18	0.0	0.0	338.5
Brew KIT	1	92.9	1.0	254.5	5.00	0.06	0.0	0.0	10.6
Dining Space	1	273.0	15.0	553.7	7.50	0.18	0.0	0.0	161.6
fwc1	1	20.1	1.0	51.7	0.00	0.00	0.0	0.0	0.0
fwc2	1	18.6	1.0	47.1	0.00	0.00	0.0	0.0	0.0
fwc3	1	20.6	1.0	50.0	0.00	0.00	0.0	0.0	0.0
fwc4	1	36.4	1.0	65.0	0.00	0.00	0.0	0.0	0.0
KEG Store	1	69.3	1.0	87.1	5.00	0.12	0.0	0.0	13.3
Mwc	1	66.6	3.0	117.8	0.00	0.00	0.0	0.0	0.0
staff	1	50.9	3.0	101.4	5.00	0.06	0.0	0.0	18.1
staff bath	1	18.0	1.0	49.4	0.00	0.00	0.0	0.0	0.0
Wash up	1	116.3	2.0	125.3	0.00	0.06	0.0	0.0	7.0
Totals (incl. Space Multipliers)				3044.6					549.0

Air System Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Aug 1600 COOLING OA DB / WB 82.4 °F / 68.0 °F			HEATING DATA AT DES HTG HEATING OA DB / WB 24.8 °F / 20.8 °F		
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	245 ft²	11952	-	245 ft²	-	-
Wall Transmission	3859 ft²	4068	-	3859 ft²	15889	-
Roof Transmission	1830 ft²	7932	-	1830 ft²	24509	-
Window Transmission	245 ft²	716	-	245 ft²	6522	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	733 ft²	1092	-	733 ft²	9944	-
Floor Transmission	1762 ft²	0	-	1762 ft²	0	-
Partitions	3367 ft²	0	-	3367 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	1555 W	4745	-	0	0	-
Task Lighting	1456 W	4657	-	0	0	-
Electric Equipment	1941 W	6386	-	0	0	-
People	50	11108	9760	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	720	930	-	0	0
Safety Factor	15% / 5%	8007	535	0%	0	0
>> Total Zone Loads	-	61384	11225	-	56864	0
Zone Conditioning	-	60918	11225	-	56111	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	3045 CFM	0	-	3045 CFM	0	-
Ventilation Load	549 CFM	1904	2375	549 CFM	13231	0
Supply Fan Load	3045 CFM	4514	-	3045 CFM	-4514	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	67335	13599	-	64828	0
Central Cooling Coil	-	67335	13604	-	0	0
Central Heating Coil	-	0	-	-	64828	-
>> Total Conditioning	-	67335	13604	-	64828	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Zone Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

Zone 1	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1900			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 79.5 °F / 67.1 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	245 ft²	8365	-	245 ft²	-	-
Wall Transmission	3859 ft²	5297	-	3859 ft²	15889	-
Roof Transmission	1830 ft²	12716	-	1830 ft²	24509	-
Window Transmission	245 ft²	495	-	245 ft²	6522	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	733 ft²	755	-	733 ft²	9944	-
Floor Transmission	1762 ft²	0	-	1762 ft²	0	-
Partitions	3367 ft²	0	-	3367 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	1555 W	4849	-	0	0	-
Task Lighting	1456 W	4715	-	0	0	-
Electric Equipment	1941 W	6429	-	0	0	-
People	50	11317	9760	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	720	930	-	0	0
Safety Factor	15% / 5%	8349	535	0%	0	0
>> Total Zone Loads	-	64007	11225	-	56864	0

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.1.A. Component Loads For Space "Bar Kitchen" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Aug 1600			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 82.4 °F / 68.0 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	165 ft²	10766	-	165 ft²	-	-
Wall Transmission	890 ft²	866	-	890 ft²	3666	-
Roof Transmission	1047 ft²	4538	-	1047 ft²	14023	-
Window Transmission	165 ft²	483	-	165 ft²	4396	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	303 ft²	452	-	303 ft²	4114	-
Floor Transmission	1047 ft²	0	-	1047 ft²	0	-
Partitions	642 ft²	0	-	642 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	890 W	2475	-	0	0	-
Task Lighting	890 W	2725	-	0	0	-
Electric Equipment	838 W	2622	-	0	0	-
People	20	3768	4100	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	240	310	-	0	0
Safety Factor	15% / 5%	4340	221	0%	0	0
>> Total Zone Loads	-	33275	4631	-	26199	0

TABLE 1.1.B. Envelope Loads For Space "Bar Kitchen" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING TRANS (BTU/hr)	COOLING SOLAR (BTU/hr)	HEATING TRANS (BTU/hr)
N EXPOSURE						
WALL	383	0.091	-	118	-	1576
DOOR	184	0.300	-	275	-	2500
S EXPOSURE						
WALL	393	0.091	-	609	-	1617
WINDOW 1	119	0.588	0.811	347	7732	3157
WINDOW 2	47	0.588	0.811	136	3033	1239
DOOR	84	0.300	-	125	-	1139
E EXPOSURE						
WALL	40	0.091	-	63	-	165
DOOR	35	0.300	-	52	-	475
W EXPOSURE						
WALL	75	0.091	-	76	-	309
H EXPOSURE						
ROOF	1047	0.296	-	4538	-	14023

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.2.A. Component Loads For Space "Brew KIT" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jun 2100			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 75.0 °F / 66.0 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	391 ft²	644	-	391 ft²	1609	-
Roof Transmission	93 ft²	671	-	93 ft²	1248	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	18 ft²	1	-	18 ft²	237	-
Floor Transmission	92 ft²	0	-	92 ft²	0	-
Partitions	205 ft²	0	-	205 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	79 W	269	-	0	0	-
Task Lighting	79 W	269	-	0	0	-
Electric Equipment	700 W	2388	-	0	0	-
People	1	295	455	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	240	310	-	0	0
Safety Factor	15% / 5%	717	38	0%	0	0
>> Total Zone Loads	-	5494	803	-	3094	0

TABLE 1.2.B. Envelope Loads For Space "Brew KIT" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING TRANS (BTU/hr)	COOLING SOLAR (BTU/hr)	HEATING TRANS (BTU/hr)
N EXPOSURE						
WALL	68	0.091	-	51	-	281
S EXPOSURE						
WALL	68	0.091	-	116	-	281
E EXPOSURE						
WALL	118	0.091	-	237	-	487
DOOR	18	0.300	-	1	-	237
W EXPOSURE						
WALL	136	0.091	-	240	-	559
H EXPOSURE						
ROOF	93	0.296	-	671	-	1248

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.3.A. Component Loads For Space "Dining Space" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jun 1900			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 78.5 °F / 67.1 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	80 ft²	2015	-	80 ft²	-	-
Wall Transmission	368 ft²	493	-	368 ft²	1514	-
Roof Transmission	273 ft²	1961	-	273 ft²	3656	-
Window Transmission	80 ft²	114	-	80 ft²	2126	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	196 ft²	143	-	196 ft²	2658	-
Floor Transmission	273 ft²	0	-	273 ft²	0	-
Partitions	143 ft²	0	-	143 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	232 W	792	-	0	0	-
Task Lighting	232 W	792	-	0	0	-
Electric Equipment	50 W	171	-	0	0	-
People	15	3675	3075	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	240	310	-	0	0
Safety Factor	15% / 5%	1559	169	0%	0	0
>> Total Zone Loads	-	11954	3554	-	9954	0

TABLE 1.3.B. Envelope Loads For Space "Dining Space" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING TRANS (BTU/hr)	COOLING SOLAR (BTU/hr)	HEATING TRANS (BTU/hr)
N EXPOSURE						
WALL	116	0.091	-	77	-	478
WINDOW 1	80	0.588	0.811	114	2015	2126
S EXPOSURE						
WALL	51	0.091	-	78	-	209
DOOR	123	0.300	-	89	-	1661
E EXPOSURE						
WALL	89	0.091	-	178	-	366
DOOR	56	0.300	-	41	-	759
W EXPOSURE						
WALL	112	0.091	-	160	-	460
DOOR	18	0.300	-	13	-	237
H EXPOSURE						
ROOF	273	0.296	-	1961	-	3656

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.4.A. Component Loads For Space "fwc1" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 2200			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 74.5 °F / 65.5 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	181 ft²	319	-	181 ft²	744	-
Roof Transmission	20 ft²	134	-	20 ft²	269	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	18 ft²	1	-	18 ft²	237	-
Floor Transmission	20 ft²	0	-	20 ft²	0	-
Partitions	170 ft²	0	-	170 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	17 W	58	-	0	0	-
Task Lighting	17 W	58	-	0	0	-
Electric Equipment	50 W	171	-	0	0	-
People	1	230	120	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	15% / 5%	146	6	0%	0	0
>> Total Zone Loads	-	1117	126	-	1251	0

TABLE 1.4.B. Envelope Loads For Space "fwc1" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING	COOLING	HEATING
				TRANS (BTU/hr)	SOLAR (BTU/hr)	TRANS (BTU/hr)
N EXPOSURE						
WALL	28	0.091	-	22	-	117
S EXPOSURE						
WALL	28	0.091	-	55	-	117
E EXPOSURE						
WALL	53	0.091	-	106	-	219
DOOR	18	0.300	-	1	-	237
W EXPOSURE						
WALL	71	0.091	-	137	-	292
H EXPOSURE						
ROOF	20	0.296	-	134	-	269

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.5.A. Component Loads For Space "fwc2" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 2100			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 76.0 °F / 66.0 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	158 ft²	241	-	158 ft²	649	-
Roof Transmission	19 ft²	129	-	19 ft²	249	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	18 ft²	6	-	18 ft²	237	-
Floor Transmission	19 ft²	0	-	19 ft²	0	-
Partitions	88 ft²	0	-	88 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	16 W	54	-	0	0	-
Task Lighting	16 W	54	-	0	0	-
Electric Equipment	50 W	171	-	0	0	-
People	1	230	120	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	15% / 5%	133	6	0%	0	0
>> Total Zone Loads	-	1017	126	-	1135	0

TABLE 1.5.B. Envelope Loads For Space "fwc2" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING TRANS (BTU/hr)	COOLING SOLAR (BTU/hr)	HEATING TRANS (BTU/hr)
N EXPOSURE						
WALL	51	0.091	-	37	-	209
S EXPOSURE						
WALL	51	0.091	-	96	-	209
E EXPOSURE						
WALL	37	0.091	-	74	-	151
W EXPOSURE						
WALL	19	0.091	-	34	-	79
DOOR	18	0.300	-	6	-	237
H EXPOSURE						
ROOF	19	0.296	-	129	-	249

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.6.A. Component Loads For Space "fwc3" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 2100			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 76.0 °F / 66.0 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	188 ft²	269	-	188 ft²	772	-
Roof Transmission	21 ft²	143	-	21 ft²	276	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	18 ft²	6	-	18 ft²	237	-
Floor Transmission	19 ft²	0	-	19 ft²	0	-
Partitions	178 ft²	0	-	178 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	18 W	60	-	0	0	-
Task Lighting	18 W	60	-	0	0	-
Electric Equipment	50 W	171	-	0	0	-
People	1	230	120	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	15% / 5%	141	6	0%	0	0
>> Total Zone Loads	-	1080	126	-	1285	0

TABLE 1.6.B. Envelope Loads For Space "fwc3" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING TRANS (BTU/hr)	COOLING SOLAR (BTU/hr)	HEATING TRANS (BTU/hr)
N EXPOSURE						
WALL	75	0.091	-	54	-	309
S EXPOSURE						
WALL	75	0.091	-	142	-	309
E EXPOSURE						
WALL	28	0.091	-	55	-	113
W EXPOSURE						
WALL	10	0.091	-	18	-	41
DOOR	18	0.300	-	6	-	237
H EXPOSURE						
ROOF	21	0.296	-	143	-	276

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.7.A. Component Loads For Space "fwc4" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 2100			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 76.0 °F / 66.0 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	227 ft²	348	-	227 ft²	936	-
Roof Transmission	36 ft²	253	-	36 ft²	487	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	18 ft²	6	-	18 ft²	237	-
Floor Transmission	19 ft²	0	-	19 ft²	0	-
Partitions	194 ft²	0	-	194 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	31 W	106	-	0	0	-
Task Lighting	31 W	106	-	0	0	-
Electric Equipment	50 W	171	-	0	0	-
People	1	230	120	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	15% / 5%	183	6	0%	0	0
>> Total Zone Loads	-	1402	126	-	1661	0

TABLE 1.7.B. Envelope Loads For Space "fwc4" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING TRANS (BTU/hr)	COOLING SOLAR (BTU/hr)	HEATING TRANS (BTU/hr)
N EXPOSURE						
WALL	72	0.091	-	52	-	295
S EXPOSURE						
WALL	72	0.091	-	136	-	295
E EXPOSURE						
WALL	51	0.091	-	102	-	209
W EXPOSURE						
WALL	33	0.091	-	59	-	137
DOOR	18	0.300	-	6	-	237
H EXPOSURE						
ROOF	36	0.296	-	253	-	487

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.8.A. Component Loads For Space "KEG Store" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 2100			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 76.0 °F / 66.0 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	343 ft²	505	-	343 ft²	1410	-
Roof Transmission	69 ft²	482	-	69 ft²	928	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	18 ft²	6	-	18 ft²	237	-
Floor Transmission	69 ft²	0	-	69 ft²	0	-
Partitions	360 ft²	0	-	360 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	59 W	201	-	0	0	-
Task Lighting	59 W	201	-	0	0	-
Electric Equipment	3 W	10	-	0	0	-
People	1	230	120	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	15% / 5%	245	6	0%	0	0
>> Total Zone Loads	-	1881	126	-	2576	0

TABLE 1.8.B. Envelope Loads For Space "KEG Store" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING	COOLING	HEATING
				TRANS (BTU/hr)	SOLAR (BTU/hr)	TRANS (BTU/hr)
N EXPOSURE						
WALL	124	0.091	-	90	-	511
S EXPOSURE						
WALL	124	0.091	-	236	-	511
E EXPOSURE						
WALL	56	0.091	-	112	-	230
W EXPOSURE						
WALL	38	0.091	-	68	-	158
DOOR	18	0.300	-	6	-	237
H EXPOSURE						
ROOF	69	0.296	-	482	-	928

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.9.A. Component Loads For Space "Mwc" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 2100			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 76.0 °F / 66.0 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	309 ft²	495	-	309 ft²	1274	-
Roof Transmission	67 ft²	464	-	67 ft²	892	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	18 ft²	6	-	18 ft²	237	-
Floor Transmission	19 ft²	0	-	19 ft²	0	-
Partitions	243 ft²	0	-	243 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	57 W	193	-	0	0	-
Task Lighting	57 W	193	-	0	0	-
Electric Equipment	50 W	171	-	0	0	-
People	3	690	360	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	15% / 5%	332	18	0%	0	0
>> Total Zone Loads	-	2543	378	-	2403	0

TABLE 1.9.B. Envelope Loads For Space "Mwc" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING TRANS (BTU/hr)	COOLING SOLAR (BTU/hr)	HEATING TRANS (BTU/hr)
N EXPOSURE						
WALL	79	0.091	-	57	-	326
S EXPOSURE						
WALL	79	0.091	-	150	-	326
E EXPOSURE						
WALL	84	0.091	-	169	-	347
W EXPOSURE						
WALL	67	0.091	-	118	-	275
DOOR	18	0.300	-	6	-	237
H EXPOSURE						
ROOF	67	0.296	-	464	-	892

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.10.A. Component Loads For Space "staff" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 2100			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 76.0 °F / 66.0 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	260 ft²	382	-	260 ft²	1071	-
Roof Transmission	51 ft²	354	-	51 ft²	682	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	35 ft²	12	-	35 ft²	475	-
Floor Transmission	51 ft²	0	-	51 ft²	0	-
Partitions	202 ft²	0	-	202 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	43 W	148	-	0	0	-
Task Lighting	43 W	148	-	0	0	-
Electric Equipment	50 W	171	-	0	0	-
People	3	690	360	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	15% / 5%	286	18	0%	0	0
>> Total Zone Loads	-	2189	378	-	2227	0

TABLE 1.10.B. Envelope Loads For Space "staff" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING	COOLING	HEATING
				TRANS (BTU/hr)	SOLAR (BTU/hr)	TRANS (BTU/hr)
N EXPOSURE						
WALL	93	0.091	-	67	-	381
S EXPOSURE						
WALL	75	0.091	-	142	-	309
DOOR	18	0.300	-	6	-	237
E EXPOSURE						
WALL	38	0.091	-	75	-	154
DOOR	18	0.300	-	6	-	237
W EXPOSURE						
WALL	55	0.091	-	98	-	226
H EXPOSURE						
ROOF	51	0.296	-	354	-	682

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.11.A. Component Loads For Space "staff bath" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 2100			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 76.0 °F / 66.0 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	164 ft²	241	-	164 ft²	676	-
Roof Transmission	18 ft²	125	-	18 ft²	241	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	18 ft²	6	-	18 ft²	237	-
Floor Transmission	18 ft²	0	-	18 ft²	0	-
Partitions	680 ft²	0	-	680 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	15 W	52	-	0	0	-
Task Lighting	15 W	52	-	0	0	-
Electric Equipment	50 W	171	-	0	0	-
People	1	280	270	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	15% / 5%	139	14	0%	0	0
>> Total Zone Loads	-	1066	284	-	1154	0

TABLE 1.11.B. Envelope Loads For Space "staff bath" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING	COOLING	HEATING
				TRANS (BTU/hr)	SOLAR (BTU/hr)	TRANS (BTU/hr)
N EXPOSURE						
WALL	62	0.091	-	44	-	254
S EXPOSURE						
WALL	62	0.091	-	117	-	254
E EXPOSURE						
WALL	29	0.091	-	58	-	120
W EXPOSURE						
WALL	12	0.091	-	21	-	48
DOOR	18	0.300	-	6	-	237
H EXPOSURE						
ROOF	18	0.296	-	125	-	241

Space Design Load Summary for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

TABLE 1.12.A. Component Loads For Space "Wash up" In Zone "Zone 1"

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jun 2000			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 76.8 °F / 66.5 °F			HEATING OA DB / WB 24.8 °F / 20.8 °F		
	OCCUPIED T-STAT 75.0 °F			OCCUPIED T-STAT 70.0 °F		
SPACE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	381 ft²	584	-	381 ft²	1569	-
Roof Transmission	116 ft²	848	-	116 ft²	1557	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	59 ft²	23	-	59 ft²	799	-
Floor Transmission	116 ft²	0	-	116 ft²	0	-
Partitions	263 ft²	0	-	263 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	99 W	337	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	0 W	0	-	0	0	-
People	2	560	540	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	15% / 5%	353	27	0%	0	0
>> Total Zone Loads	-	2706	567	-	3926	0

TABLE 1.12.B. Envelope Loads For Space "Wash up" In Zone "Zone 1"

	Area (ft²)	U-Value (BTU/(hr-ft²-°F))	Shade Coeff.	COOLING TRANS (BTU/hr)	COOLING SOLAR (BTU/hr)	HEATING TRANS (BTU/hr)
N EXPOSURE						
WALL	88	0.091	-	62	-	364
S EXPOSURE						
WALL	47	0.091	-	77	-	193
DOOR	41	0.300	-	16	-	561
E EXPOSURE						
WALL	132	0.091	-	264	-	542
W EXPOSURE						
WALL	114	0.091	-	182	-	470
DOOR	18	0.300	-	7	-	237
H EXPOSURE						
ROOF	116	0.296	-	848	-	1557

System Psychrometrics for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

August DESIGN COOLING DAY, 1600

TABLE 1: SYSTEM DATA

Component	Location	Dry-Bulb Temp (°F)	Specific Humidity (lb/lb)	Airflow (CFM)	CO2 Level (ppm)	Sensible Heat (BTU/hr)	Latent Heat (BTU/hr)
Ventilation Air	Inlet	82.4	0.01135	549	400	1904	2375
Ventilation Reclaim	Outlet	79.2	0.01044	549	400	1904	2369
Vent - Return Mixing	Outlet	76.6	0.00969	3045	1232	-	-
Central Cooling Coil	Outlet	56.1	0.00875	3045	1232	67335	13604
Central Heating Coil	Outlet	56.1	0.00875	3045	1232	0	-
Supply Fan	Outlet	57.4	0.00875	3045	1232	4514	-
Cold Supply Duct	Outlet	57.4	0.00875	3045	1232	-	-
Zone Air	-	76.0	0.00953	3045	1415	60918	11225
Return Plenum	Outlet	76.0	0.00953	3045	1415	0	-

Air Density x Heat Capacity x Conversion Factor: At sea level = 1.080; At site altitude = 1.079 BTU/(hr-CFM-F)

Air Density x Heat of Vaporization x Conversion Factor: At sea level = 4746.6; At site altitude = 4743.8 BTU/(hr-CFM)

Site Altitude = 16.4 ft

TABLE 2: ZONE DATA

Zone Name	Zone Sensible Load (BTU/hr)	T-stat Mode	Zone Cond (BTU/hr)	Zone Temp (°F)	Zone Airflow (CFM)	CO2 Level (ppm)	Terminal Heating Coil (BTU/hr)	Zone Heating Unit (BTU/hr)
Zone 1	61384	Cooling	60918	76.0	3045	1415	0	0

System Psychrometrics for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

WINTER DESIGN HEATING

TABLE 1: SYSTEM DATA

Component	Location	Dry-Bulb Temp (°F)	Specific Humidity (lb/lb)	Airflow (CFM)	CO2 Level (ppm)	Sensible Heat (BTU/hr)	Latent Heat (BTU/hr)
Ventilation Air	Inlet	24.8	0.00134	549	400	-13231	0
Ventilation Reclaim	Outlet	47.1	0.00134	549	400	-13231	0
Vent - Return Mixing	Outlet	65.4	0.00134	3045	445	-	-
Central Cooling Coil	Outlet	65.4	0.00134	3045	445	0	0
Central Heating Coil	Outlet	85.2	0.00134	3045	445	64828	-
Supply Fan	Outlet	86.5	0.00134	3045	445	4514	-
Cold Supply Duct	Outlet	86.5	0.00134	3045	445	-	-
Zone Air	-	69.5	0.00134	3045	455	-56111	0
Return Plenum	Outlet	69.5	0.00134	3045	455	0	-

Air Density x Heat Capacity x Conversion Factor: At sea level = 1.080; At site altitude = 1.079 BTU/(hr-CFM-F)

Air Density x Heat of Vaporization x Conversion Factor: At sea level = 4746.6; At site altitude = 4743.8 BTU/(hr-CFM)

Site Altitude = 16.4 ft

TABLE 2: ZONE DATA

Zone Name	Zone Sensible Load (BTU/hr)	T-stat Mode	Zone Cond (BTU/hr)	Zone Temp (°F)	Zone Airflow (CFM)	CO2 Level (ppm)	Terminal Heating Coil (BTU/hr)	Zone Heating Unit (BTU/hr)
Zone 1	-56864	Heating	-56111	69.5	3045	455	0	0

System Psychrometrics for Rest - Floor 1 Zone 1


Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

Location: London - Kew, United Kingdom

Altitude: 16.4 ft.

Data for: August DESIGN COOLING DAY, 1600



System Psychrometrics for Rest - Floor 1 Zone 1

Project Name: Project 113
Prepared by: Engineer's Team

11/09/2024
11:49AM

Location: London - Kew, United Kingdom
Altitude: 16.4 ft.
Data for: WINTER DESIGN HEATING

